



Ref. Certif. No.

HU-002466

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

**Product**

PV Switch-disconnector

**Name and address of the applicant**

Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone, Beibaixiang Yueqing,  
P.R. China

**Name and address of the manufacturer**

Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone, Beibaixiang Yueqing,  
P.R. China

**Name and address of the factory**

Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone, Beibaixiang Yueqing,  
P.R. China

*Note: When more than one factory, please report on page 2*

**Ratings and principal characteristics**

Ui=1500V; Uimp=8kV; -40°C to +85°C; No polarity;  
DC-PV2, Ue: 300/600/1000/1200/1500 DC, Ie: 16A...50A;  
IP66 (BYSS-50), IP20 (BYSS.1-50, BYSS.2-50);  
Ith/Ithe=50A; Icw=1,5kA, 1s; Icm=2kA  
(refer to Test item particulars and General product  
information of Test Report for further details)

**Trademark (if any)**

ZJBENY

**Customer's Testing Facility (CTF) Stage used**

---

**Model / Type Ref.**

BYSS-50, BYSS.1-50, BYSS.2-50

**Additional information (if necessary may also be reported on page 2)**

---


**A sample of the product was tested and found to be in conformity with**

IEC 60947-3:2008 + AMD1:2012 + AMD2:2015  
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014

**As shown in the Test Report Ref. No. which forms part of this Certificate**

1C182098

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com

Date: 2019-01-25

Signature:

*Gabor Kassai*  
Gabor Kassai

